



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

PHYSICAL AND CHEMICAL TEST REPORTS:


Date Of Collection	15.07.2025
Date Of Analysis	15.07.2025
Date Of Reporting	16.07.2025


SL. NO.	Parameters	Acceptable Limit (as per IS 10500 : 2012)	Cause of Rejection	RESULT	
				Place Source	Nepania Busty, Mirjangla Well (With Filter)
				Sender	Dr. Ambedkar Academy
1.	Turbidity (NTU)	1	5		0.26
2.	pH	6.5 to 8.5	No Relaxation		7.04
3.	TDS(ppm)	500	2000		14
4.	Iron (mg/l)	1.0	No Relaxation		0.03
5.	Res. Chlorine (mg/l)	0.2	1.0		0
6.	Fluoride (mg/l)	1.0	1.5		0.032
7.	Total Hardness(mg/l)	200	600		8
8.	Total Alkalinity(mg/l)	200	600		12

*The tests done with the Sample as deposited by the Party.

Physical & Chemical Test Charge Rs. 900.00/-

Received Vide GRN No. 192025260143158408 Dated: 04/07/2025


Chemist/Bacteriologist,
Darjeeling District Laboratory,
Fulbari, W.T.P.



Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Memo No.....2284 /swsd...../SD: Dated, Siliguri, the...22.07.2025

Copy forwarded for information and necessary action to:-

1. Dr. Ambedkar Academy.
2. Office Copy.

Report No: Chem/2025/July-19


Assistant Engineer-II,
Siliguri Water Supply Division,
P.H. Engineering Dte.


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 842/PHE/2025

Dated: 7/04/2025

It is certified that an inspection team headed by Sanjit Sarkar, Junior Engineer (Name of Officers with designation) from Public Health Department, Siliguri (Name of Department/Office) inspected the Dr. Ambedkar Academy at Nepania Busty, Mirjangla, P.O. Belgachi P.S. Naxalbari, District Darjeeling West Bengal (Name & Address of the school) on 23/07/2025 (date of inspection) and found that the Dr. Ambedkar Academy (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One Year.

Signature with Seal: 
Name : P.H. Engineering Dte.
Designation : Siliguri
Name & Address of the Office/ Department:

To,
Dr. Ambedkar Academy
Nepania Busty, Mirjangla,
P.O. Belgachi, P.S. Naxalbari,
District Darjeeling, West Bengal